



Long Beach Fire Department Bureau of Fire Prevention

FIRE PREVENTION REQUIREMENT NO. 4.003	5/08
--	------

PARADE FLOATS

1. A permit to operate float is required.
2. All decorative material shall be non-combustible or flame retardant.
3. All floats and towing apparatus shall have a minimum 2A 10BC extinguisher.
4. Portable generators to be located so exhaust gas has proper clearance from any combustibles and is not in a closed area with occupants.
5. Vehicle tail pipe has clearance from any combustible material.
6. Safety precautions for occupants riding on float railings, hand holds, seating stability.
7. "No Smoking" signs posted
8. Field inspection prior to parade.