



FORM-019

**Express Permit Checklist for One- and Two-Family EVCS**

This Express Permit Checklist (Checklist) applies to minor construction work to install an electrical vehicle charging station (EVCS) and related equipment to existing one- or two-family dwelling buildings. This Checklist is intended to be a simple check to demonstrate reasonable assurance that the design and installation of an EVCS complies with the 2022 Edition of the California Electrical Code (CEC), California Building Code (CBC), and California Green Building Standards Code (CGBSC). If a project meets the criteria on this Checklist (all boxes are marked as “Y”), then the need for a formal plan review submittal MAY be avoided and a streamlined permit issuance process may be granted. Refer to Information Bulletin [IB-049](#) Permitting Process for EVCS for additional information.

The following words and terms used in this form are defined in the CBC Chapter 2, CGBSC Chapter 2, and/or CEC Article 625. They shall have the following meaning:

*Electric Vehicle (EV) Charger. Off-board charging equipment used to charge an EV.*

*Electric Vehicle Charging Space (EV Space). A space intended for future installation of EV charging equipment and charging of EVs.*

*Electric Vehicle Charging Station (EVCS). One or more EV Spaces served by EV Charger(s) or other charging equipment allowing charging of EVs. EVCS are not considered parking spaces (for building code purposes).*

*Electric Vehicle Supply Equipment (EVSE). The conductors, including the ungrounded, grounded, and equipment grounding conductors and the EV connectors, attachment plugs, and all other fittings, devices, power outlets, or apparatus installed specifically for the purpose of transferring energy between the premises wiring and the EV.*

**PROJECT INFORMATION** (please check boxes)

- Please identify the type, location, and quantity of EVSE proposed; identify if an electrical panel upgrade is required; and identify the type of mounting for EVSE.

TYPE OF EVSE	check one
110/120 VAC, 15A or 20A	<input type="checkbox"/>
208/240 VAC, 20A or 30A	<input type="checkbox"/>
208/240 VAC, 40A	<input type="checkbox"/>
208/240 VAC, 50A	<input type="checkbox"/>

LOCATION	check one
Within Garage	<input type="checkbox"/>
Under Carport	<input type="checkbox"/>
Outside	<input type="checkbox"/>
Other	<input type="checkbox"/>

QUANTITY	check one
1 EVSE total	<input type="checkbox"/>
2 EVSE total; same panel	<input type="checkbox"/>
2 EVSE total; 1 per panel	<input type="checkbox"/>

PANEL UPGRADE	check one
No – Not Required	<input type="checkbox"/>
Yes – Panel Rated at Min. 225A	<input type="checkbox"/>

TYPE OF MOUNTING	check one
Wall Receptacle	<input type="checkbox"/>
Wall Mount	<input type="checkbox"/>
Pole Mount	<input type="checkbox"/>

**GENERAL REQUIREMENTS**

(please check box, Y = Yes or True, N = No or False)

2. [APP-012](#) Express Electrical Permit Application is completed and attached along with this Checklist that include, but not limited to, the following information:  Y  N
- Property address;
  - Name, address, phone number of the property owner; and
  - Name, address, phone number and license number of the person responsible for the EVCS system design and/or installation
3. [FORM-028](#) Plot Plan is completed and attached along with this Checklist that include, but not limited to, the following information:  Y  N
- Location of the existing building(s) or structure(s) on the site;
  - Property lines, streets, lot dimensions, north arrow, the distance from property lines to the building(s) or structure(s) and the proposed EVCS location;
  - Location of existing meter, proposed EVSE equipment, existing/new electrical panel, disconnect and overcurrent protection;
  - Identify existing/new electrical panel amperage; show where conduit and/or trenching is/are proposed, and reflects the information contained in this Checklist

**PLANNING REQUIREMENTS**

(please check box, Y = Yes or True, N = No or False)

4. EVCS is not located in a Coastal Zone  Y  N
5. EVCS is not located in a Historic District or on a qualified historical building or property  Y  N

**ELECTRICAL REQUIREMENTS**

(please check box, Y = Yes or True, N = No or False)

6. EVSE will be installed in accordance with CEC 625  Y  N
7. EVSE will be installed in accordance with the Manufacturer's installation guideline, must be suitable for the environment (indoor vs outdoor), and made available for inspection upon request by City Inspector  Y  N
8. EVSE and related equipment will be UL listed and marked (or other approved Nationally Recognized Testing Laboratory listing and marking) in accordance with UL 2202 and UL 2594 per CBC 406.2.7  Y  N
9. Electrical service load calculations will be performed to determine that the electrical panel is adequately sized and has sufficient electrical capacity in accordance with CEC 220  Y  N
10. Installation will not have line side or load side tap connections  Y  N
11. Electrical panel will have the required breaker slot(s) to accommodate the EVSE installation  Y  N
12. EVSE coupling means will be mounted at a height not less than 18" (indoor use) **OR** 24" (outdoor use) from the finished floor or grade per CEC 625.50, unless specifically instructed otherwise by the Manufacturer's installation guideline  Y  N
13. EVSE will have sufficient working space (30" wide, 36" depth, 78" high) for safe operation and maintenance per CEC 110.26  Y  N
14. Copper wire conductor size will not exceed a length of 75'-0", installed within a min. 1" conduit, and comply with the following information shown below per CEC Table 310.15(B)(16) (based on 60°C, Types TW, UF):  Y  N
- Provide #12 AWG conductors for 20A circuit; or
  - Provide #10 AWG conductors for 30A circuit; or
  - Provide #8 AWG conductors for 40A circuit; or
  - Provide #6 AWG conductors for 50A; **AND**
  - Provide a readily accessible disconnecting means for the EVSE and capable of being locked in the open position per CEC 625.43 and CEC 110.25
15. Where EVSE is used in an indoor enclosed space, ventilation is not required for EVSE marked by the Manufacturer as "Ventilation Not Required" **OR** EVSE marked by the Manufacturer as "Ventilation Required" will be provided with a ventilation system for intake supply air and vent the exhaust to the outdoor per CEC 625.52 and CBC 406.9.2  Y  N
16. EVSE receptacle is GFCI or is hard-wired per CEC 625.54  Y  N
17. Where trenching is required, a min. 18" cover will be provided for direct-buried cables or conductors per CEC Table 300.5  Y  N
18. EVSE will be protected by a safety bollard where potential striking may exist per CEC 110.27(B) as determined by the City Inspector; bollard will typically be a min. 36" tall x min. 3" diameter steel pipe filled with concrete, embedded a min. 24" into a min. 36" deep x 12" diameter concrete footing, and distanced a min 12" from the EVSE  Y  N
19. Utility provider's (SCE) notification/approval will be provided/obtained where a new, upgrade, relocated, or dedicated electric meter is required prior to or part of the EVSE installation  Y  N

Complete and submit the [APP-012](#) Express Electrical Permit Application and [FORM-028](#) Plot Plan to the Building and Safety Bureau to begin the express permit issuance process. Refer to Information Bulletin [IB-049](#) Permitting Process for EVCS and Information Bulletin [IB-058](#) Express Permit Service and for additional information.

### ACKNOWLEDGMENT STATEMENT

I/We, the undersigned contractor(s)/installer(s) responsible for the design and installation of an EVSE, understand that the permit will be issued based upon the checked "Y" and completing the required information to all of the above questions. I/We understand that if any questions are checked "N" or incomplete information to all of the above questions, I/We will revise the design to fit the criteria of this Checklist; otherwise the permit application may be required to go through the standard plan review process. I/We acknowledge that the construction documents, which are neither reviewed nor approved by the City, reflect the criteria of this Checklist. I/We assume all risk/responsibility if the installation of the work deviates from this Checklist and will strictly adhere to all code requirements and make the necessary changes to the installation. I/We understand that this permit conveys no vested rights in the event a conflict with any codes, local ordinances, and state laws are later identified as part of the inspection process. We further understand that any correction, removal or change of any portion of the installation will be done at the sole expense/liability of the contractor(s)/installer(s).

Job Address: \_\_\_\_\_ Permit #: \_\_\_\_\_

Permittee: \_\_\_\_\_ License # & Class: \_\_\_\_\_

Signature: \_\_\_\_\_ Date: \_\_\_\_\_ Phone #: \_\_\_\_\_

To request this information in an alternative format or to request a reasonable accommodation, please contact the Community Development Department at [longbeach.gov/lbcd](http://longbeach.gov/lbcd) and 562.570.3807. A minimum of three business days is requested to ensure availability; attempts will be made to accommodate requests with shorter notice.