



NOTES:

1. A No. 5 pull box shall be installed adjacent to all street light standards.
2. Conduit shall be 25 mm (1'') Sch 40 PVC unless otherwise noted.
3. Series Circuits - Connect conductors to remote ballast in pull box.
4. Multiple Circuits - Connect conductors to fuseholder in pull box. See Standard Plan LB-713.
5. Bond wire shall be same size as conductor wire between street light pull boxes.
6. See Standard Plan LB-716 for additional notes.

Dimensions are in millimeters, except as noted

REVISIONS		CITY OF LONG BEACH, CALIFORNIA DEPARTMENT OF PUBLIC WORKS	STANDARD PLAN NO.
NO.	DATE		METRIC 709
1	01/22/98	PULL BOX AND STREET LIGHT CONDUIT AND CONDUCTOR DETAILS	SHEET 1 OF 1
2	12/23/02		
3		APPROVED BY: <i>Mark D. J. [Signature]</i>	DATE: <i>1/19/03</i>
4		CITY ENGINEER R.E. No. <i>40599</i>	EX. DATE: <i>03/31/03</i>